

NORTHERN NEVADA PUBLIC HEALTH AIR QUALITY MANAGEMENT DIVISION 1001 East Ninth Street Suite B171 Reno, Nevada 89512

NOTICE OF VIOLATION No: AQMV24-0032 ISSUED TO

Owner: 840 I Street, LLC Location: 840 I Street Sparks, NV 89431, APN 031-081-51 Date of Issuance: December 9, 2024 Case No.: 1504

Northern Nevada Public Health Air Quality Management Division (AQMD) has determined that 840 I Street, LLC is in violation of the District Board of Health Regulations Governing Air Quality Management PART 030.105 – NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS.

1. VIOLATION

A. Failure to thoroughly inspect the affected facility or part of the facility where the renovation operation will occur for the presence of asbestos as required by 40 CFR 61.145(a).

2. BASIS OF VIOLATION

A. Regulatory Authority

The District Board of Health Regulations Governing Air Quality Management paragraph 030.105.b.10., The District Board of Health Regulations Governing Air Quality Management adopted by reference, 40 CFR 61, Subpart M and has been delegated authority to implement and ensure compliance with this Subpart within Washoe County.

Per 40 CFR 61, Subpart M – National Emission Standards for Asbestos §61.145 Standards for demolition and renovation (a) Applicability:

- (a) Applicability. To determine which requirements of paragraphs (a), (b), and (c) of this section apply to the owner or operator of a demolition or renovation activity and prior to the commencement of the demolition or renovation, thoroughly inspect the affected facility or part of the facility where the demolition or renovation operation will occur for the presence of asbestos, including Category I and Category II nonfriable ACM. The requirements of paragraphs (b) and (c) of this section apply to each owner or operator of a demolition or renovation activity, including the removal of RACM as follows:
- (4) In a facility being renovated, including any individual nonscheduled renovation operation, all the requirements of paragraphs (b) and (c) of this section apply if the combined amount of RACM to be stripped, removed, dislodged, cut, drilled, or similarly disturbed is
- (i) At least 80 linear meters (260 linear feet) on pipes or at least 15 square meters (160 square feet) on other facility components, or

Subject: Notice of Violation No. AQMV24-0032/840 I Street, LLC

Date: December 9, 2024

Page 2 of 2



(ii) At least 1 cubic meter (35 cubic feet) off facility components where the length or area could not be measured previously.

- (iii) To determine whether paragraph (a)(4) of this section applies to planned renovation operations involving individual nonscheduled operations, predict the combined additive amount of RACM to be removed or stripped during a calendar year of January 1 through December 31.
- (iv) To determine whether paragraph (a)(4) of this section applies to emergency renovation operations, estimate the combined amount of RACM to be removed or stripped as a result of the sudden, unexpected event that necessitated the renovation.
- B. Facts to Constitute the Violation
 On April 8, 2024, the AOMD four

On April 8, 2024, the AQMD found that suspect asbestos containing materials had been disturbed and removed from the property situated at 840 I Street in Sparks, Nevada. The asbestos removal occurred over the weekend of April 6-7, 2024. An asbestos survey had not been completed prior to the disturbance of the suspect asbestos containing material for the project. Following contact with the AQMD, an asbestos survey was completed on April 11, 2024. The survey indicated the presence of asbestos in the materials disturbed as part of the project.

3. APPEAL PROCEDURE AND TIME LIMITATIONS

A. Appeal Procedure

840 I Street, LLC is advised that within (10) working days of the receipt of this Notice of Violation, 840 I Street, LLC may submit a written petition for appeal to the Northern Nevada Public Health - Air Quality Hearing Board. The written petition for appeal shall be submitted to the AQMD at the following address:

Northern Nevada Public Health Air Quality Management Division 1001East Ninth Street Suite B171 Reno, Nevada 89512

Failure to submit a petition for appeal within the specified timeframe will result in the submission of this Notice of Violation to the Northern Nevada Public Health - District Board of Health with a recommendation for the assessment of an administrative fine of \$10,000.00.

12/9/24

Date

Jøshua C. Restori

Supervisor, Permitting and Compliance Air Quality Management Division Northern Nevada Public Health



NORTHERN NEVADA PUBLIC HEALTH AIR QUALITY MANAGEMENT DIVISION 1001 East Ninth Street Suite B171 Reno, Nevada 89512

NOTICE OF VIOLATION No: AQMV24-0033 ISSUED TO

Owner: 840 I Street, LLC Location: 840 I Street Sparks, NV 89431, APN 031-081-51 Date of Issuance: December 9, 2024 Case No.: 1504

Northern Nevada Public Health Air Quality Management Division (AQMD) has determined that 840 I Street, LLC is in violation of the District Board of Health Regulations Governing Air Quality Management PART 030.105 – NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS.

1. VIOLATION

A. Failure to provide written notice 10-working days in advance to the AQMD of the intention to renovate as required by 40 CFR 61.145(b).

2. BASIS OF VIOLATION

A. Regulatory Authority

The District Board of Health Regulations Governing Air Quality Management paragraph 030.105.b.10., The District Board of Health Regulations Governing Air Quality Management adopted by reference, 40 CFR 61, Subpart M and has been delegated authority to implement and ensure compliance with this Subpart within Washoe County.

Per 40 CFR. 61, Subpart M – National Emission Standards for Asbestos §61.145 Standards for demolition and renovation (b) Notification requirements:

- (b) Notification requirements. Each owner or operator of a demolition or renovation activity to which this section applies shall:
- (1) Provide the Administrator with written notice of intention to demolish or renovate. Delivery of the notice by U.S. Postal Service, commercial delivery service, or hand delivery is acceptable.
- (2) Update notice, as necessary, including when the amount of asbestos affected changes by at least 20 percent.
- (3) Postmark or deliver the notice as follows:
- (i) At least 10 working days before asbestos stripping or removal work or any other activity begins (such as site preparation that would break up, dislodge or similarly disturb asbestos material), if the operation is described in paragraphs (a) (1) and (4) (except (a)(4)(iii) and

Subject: Notice of Violation No. AQMV24-0033/840 I Street, LLC

Date: December 9, 2024

Page 2 of 2



(a)(4)(iv)) of this section. If the operation is as described in paragraph (a)(2) of this section, notification is required 10 working days before demolition begins.

B. Facts to Constitute the Violation

On April 8, 2024 the AQMD found that suspect asbestos containing materials had been disturbed and removed from the property situated at 840 I Street on April 6 & 7, 2024. The required 10-working day notification of intention to renovate required by 40 CFR 61.145(b) had not been submitted to the AQMD. Following notification by the AQMD, an abatement contractor was hired to perform asbestos abatement and cleanup. The contractor submitted the required NESHAP Notification paperwork to the AQMD on April 29, 2024 for the post asbestos disturbance abatement and cleanup activities.

3. APPEAL PROCEDURE AND TIME LIMITATIONS

A. Appeal Procedure

840 I Street, LLC is advised that within (10) working days of the receipt of this Notice of Violation, 840 I Street LLC may submit a written petition for appeal to the Northern Nevada Public Health - Air Quality Hearing Board. The written petition for appeal shall be submitted to the AQMD at the following address:

Northern Nevada Public Health Air Quality Management Division 1001East Ninth Street Suite B171 Reno, Nevada 89512

Failure to submit a petition for appeal within the specified timeframe will result in the submission of this Notice of Violation to the Northern Nevada Public Health - District Board of Health with a recommendation for the assessment of an administrative fine of \$2,000.00.

12/9/28

Date

Joshua C. Restori

Supervisor, Permitting and Compliance Air Quality Management Division Northern Nevada Public Health



NORTHERN NEVADA PUBLIC HEALTH AIR QUALITY MANAGEMENT DIVISION 1001 East Ninth Street Suite B171 Reno, Nevada 89512

NOTICE OF VIOLATION No: AQMV24-0034 ISSUED TO

Owner: 840 I Street, LLC Location: 840 I Street Sparks, NV 89431, APN 031-081-51 Date of Issuance: December 9, 2024 Case No.: 1504

Northern Nevada Public Health Air Quality Management Division (AQMD) has determined that 840 I Street, LLC is in violation of the District Board of Health Regulations Governing Air Quality Management PART 030.105 – NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS.

1. VIOLATION

A. Failure to follow proper procedures for asbestos emission control as required by 40 CFR 61.145(c)(6).

2. BASIS OF VIOLATION

A. Regulatory Authority
The District Board of Health Regulations Governing Air Quality Management paragraph
030.105.b.10., The District Board of Health Regulations Governing Air Quality Management
adopted by reference, 40 CFR 61, Subpart M and has been delegated authority to implement
and ensure compliance with this Subpart within Washoe County.

Per 40 CFR. 61, Subpart M – National Emission Standards for Asbestos §61.145 Standards for demolition and renovation (c) Procedures for asbestos emission control:

- (c) Procedures for asbestos emission control. Each owner or operator of a demolition or renovation activity to whom this paragraph applies, according to paragraph (a) of this section, shall comply with the following procedures:
- (6) For all RACM, including material that has been removed or stripped:
- (i) Adequately wet the material and ensure that it remains wet until collected and contained or treated in preparation for disposal in accordance with § 61.150; and
- (ii) Carefully lower the material to the ground and floor, not dropping, throwing, sliding, or otherwise damaging or disturbing the material.
- (iii) Transport the material to the ground via leak-tight chutes or containers if it has been removed or stripped more than 50 feet above ground level and was not removed as units or in sections.

Subject: Notice of Violation No. AQMV24-0034/840 I Street, LLC

Date: December 9, 2024

Page 2 of 2



(iv) RACM contained in leak-tight wrapping that has been removed in accordance with paragraphs (c)(4) and (c)(3)(i)(B)(3) of this section need not be wetted.

B. Facts to Constitute the Violation

On April 8, 2024, the AQMD identified regulated asbestos containing materials had been disturbed and removed from the property situated at 840 I Street in Sparks, Nevada. The asbestos removal occurred over the weekend of April 6-7, 2024.

Improper procedures used during the removal operation led to contamination of the suite, hallways, and other areas inside and on the exterior of the building at 840 I Street. In addition, the materials were openly transported from the suite and openly deposited into a dumpster in the parking lot. None of these materials were determined to be adequately wet, transported in leak-tight wrapping or deposited in a regulated landfill accepting regulated asbestos material waste.

3. APPEAL PROCEDURE AND TIME LIMITATIONS

A. Appeal Procedure

840 I Street, LLC is advised that within (10) working days of the receipt of this Notice of Violation, 840 I Street, LLC may submit a written petition for appeal to the Northern Nevada Public Health - Air Quality Hearing Board. The written petition for appeal shall be submitted to the AQMD at the following address:

Northern Nevada Public Health Air Quality Management Division 1001East Ninth Street Suite B171 Reno, Nevada 89512

Failure to submit a petition for appeal within the specified timeframe will result in the submission of this Notice of Violation to the Northern Nevada Public Health - District Board of Health with a recommendation for the assessment of an administrative fine of \$20,000.00.

12/9/24

Date

Joshua C. Restori

Supervisor, Permitting and Compliance Air Quality Management Division Northern Nevada Public Health



NORTHERN NEVADA PUBLIC HEALTH AIR QUALITY MANAGEMENT DIVISION 1001 East Ninth Street Suite B171 Reno, Nevada 89512

NOTICE OF VIOLATION No: AQMV24-0035 ISSUED TO

Owner: 840 I Street, LLC Location: 840 I Street Sparks, NV 89431, APN 031-081-51 Date of Issuance: December 9, 2024 Case No.: 1504

Northern Nevada Public Health Air Quality Management Division (AQMD) has determined that 840 I Street, LLC is in violation of the District Board of Health Regulations Governing Air Quality Management PART 030.105 – NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS.

1. VIOLATION

A. Failure to have at least one on-site representative trained in the provisions of 40 CFR 61 Subpart M onsite at the time of renovation as required by 40 CFR 61.145(c)(8).

2. BASIS OF VIOLATION

A. Regulatory Authority
The District Board of Health Regulations Governing Air Quality Management paragraph
030.105.b.10., The District Board of Health Regulations Governing Air Quality Management
adopted by reference, 40 CFR 61, Subpart M and has been delegated authority to implement
and ensure compliance with this Subpart within Washoe County.

Per 40 CFR 61, Subpart M – National Emission Standards for Asbestos §61.145 Standards for demolition and renovation(c) Procedures for asbestos emission control:

- (c) Procedures for asbestos emission control. Each owner or operator of a demolition or renovation activity to whom this paragraph applies, according to paragraph (a) of this section, shall comply with the following procedures:
- (8) Effective 1 year after promulgation of this regulation, no RACM shall be stripped, removed, or otherwise handled or disturbed at a facility regulated by this section unless at least one on-site representative, such as a foreman or management-level person or other authorized representative, trained in the provisions of this regulation and the means of complying with them, is present. Every 2 years, the trained on-site individual shall receive refresher training in the provisions of this regulation. The required training shall include as a minimum: applicability; notifications; material identification; control procedures for removals including, at least, wetting, local exhaust ventilation, negative pressure enclosures, glove-bag procedures, and High Efficiency Particulate Air (HEPA) filters; waste disposal work practices; reporting and recordkeeping; and asbestos hazards and worker protection.

Subject: Notice of Violation No. AQMV24-0035/840 I Street, LLC

Date: December 9, 2024

Page 2 of 2



Evidence that the required training has been completed shall be posted and made available for inspection by the Administrator at the demolition or renovation site.

B. Facts to Constitute the Violation

On April 8, 2024, the AQMD identified regulated asbestos containing materials had been disturbed and removed from the property situated at 840 I Street in Sparks, Nevada. The asbestos removal occurred over the weekend of April 6-7, 2024.

Based on the investigation by the AQMD, the removal of the regulated asbestos containing materials on April 6-7, 2024, at 840 I Street was completed by an individual who was not trained in the provisions of 40 CFR 61, Subpart M – National Emissions Standards for Asbestos.

3. APPEAL PROCEDURE AND TIME LIMITATIONS

A. Appeal Procedure

840 I Street, LLC is advised that within (10) working days of the receipt of this Notice of Violation, 840 I Street, LLC may submit a written petition for appeal to the Northern Nevada Public Health - Air Quality Hearing Board. The written petition for appeal shall be submitted to the AQMD at the following address:

Northern Nevada Public Health Air Quality Management Division 1001East Ninth Street Suite B171 Reno, Nevada 89512

Failure to submit a petition for appeal within the specified timeframe will result in the submission of this Notice of Violation to the Northern Nevada Public Health - District Board of Health with a recommendation for the assessment of an administrative fine of \$10,000.00.

12/9/24

Date

Joshua C. Restori

Supervisor, Permitting and Compliance Air Quality Management Division Northern Nevada Public Health



NORTHERN NEVADA PUBLIC HEALTH AIR QUALITY MANAGEMENT DIVISION 1001 East Ninth Street Suite B171 Reno, Nevada 89512

NOTICE OF VIOLATION No: AQMV24-0036 ISSUED TO

Owner: 840 I Street LLC Location: 840 I Street Sparks, NV 89431, APN 031-081-51 Date of Issuance: December 9, 2024 Case No.: 1504

Northern Nevada Public Health Air Quality Management Division (AQMD) has determined that 840 I Street, LLC is in violation of the District Board of Health Regulations Governing Air Quality Management PART 020.100 B – Stop Work Order (Suspension).

1. VIOLATION

A. Failure to comply with Stop Work Order (SWO) No. 000009.

2. BASIS OF VIOLATION

A. Regulatory Authority

The District Board of Health Regulations Governing Air Quality Management SECTION 020.100 B - Stop Work Order (Suspension):

- 1. A stop work order may be issued at any time by the Control Officer upon their determination that there has been a violation with any of the provisions of these regulations, any applicable requirement, or any condition of the permit with the potential to impact public health.
- 2. A person served with a stop work order:
 - a. Shall stop all activities specified in the stop work order as soon as safely practicable.
 - b. May apply to the Control Officer for its revocation at any time, setting forth the facts upon which they believe that the reasons for the issuance of the stop work order no longer exist.
 - c. May apply to the Hearing Board for its revocation at any time, setting forth the facts upon which they believe that the reasons for the issuance of the stop work order no longer exist.

B. Facts to Constitute the Violation

On April 9, 2024 the AQMD issued SWO No. 000009 which concerned activities related to the improper removal of regulated asbestos containing materials from 840 I St., Sparks, NV 89431.

During the time period between April 12-14, 2024, the AQMD determined additional asbestos containing materials had been scraped from the ceiling of the Units 3 and 6, asbestos containing waste materials and asbestos contaminated construction debris had been removed from Units 3 and 6 and the affected area, posted SWO's had been removed from the doors,

Subject: Notice of Violation No. AQMV24-0036/840 I Street, LLC

Date: December 9, 2024

Page 2 of 2



and the taped door jambs had been disturbed and removed. These actions are a violation of SWO No. 000009.

3. APPEAL PROCEDURE AND TIME LIMITATIONS

A. Appeal Procedure

840 I Street, LLC is advised that within (10) working days of the receipt of this Notice of Violation, 840 I Street, LLC may submit a written petition for appeal to the Northern Nevada Public Health - Air Quality Hearing Board. The written petition for appeal shall be submitted to the AQMD at the following address:

Northern Nevada Public Health Air Quality Management Division 1001East Ninth Street Suite B171 Reno, Nevada 89512

Failure to submit a petition for appeal within the specified timeframe will result in the submission of this Notice of Violation to the Northern Nevada Public Health - District Board of Health with a recommendation for the assessment of an administrative fine of \$10,000.00.

12/9/24

Date


Joshua C. Restori

Supervisor, Permitting and Compliance Air Quality Management Division Northern Nevada Public Health

Company Name Contact Name Case Number	840 Street LLC Farshad Moftakhar 1504			
Niolation of Section Recommended Per	40 CFR 61, Subpart M 61.145(a)	#	\$_	10000.00
II. Violation of Section	40 CFR 61, Subpart M 61.145(b)			
II. Recommended Pe	nalty	=	\$_	2000.00
III. Violation of Section 40 CFR 61, Subpart M 61.145(c)(6) = \$ 20000.00				20000.00
III. Recommended Pe	nalty	=	-	20000.00
IV. Violation of Section	40 CFR 61, Subpart M 61.145(c)(8	3)		
IV. Recommended Pe	nalty	=	\$_	10000.00
V. Violation of Section 030.1401 - Stop Work Order				
V. Recommended Pe	enalty	=	\$_	10000.00
Total Recommended Penalty = \$ 52,000.00			52,000.00	
Senior AQ Specialist/Supervisor 12/9/24 Date				


Com	ipany Name	840 Street LLC	
	tact Name	Farshad Moftakhar	
Case	Number	1504	
Viola	ation Number	AQMV24-0032	
Viola	ation of Section	40 CFR 61, Subpart M 61.145(a)	-
Perr	nit Condition	N/A	_
I.	Base Penalty as specified in the Penalty Table = \$ 5,000.00		
II.	Severity of Violation	n	
	A. Public Health Im	pact	
	1. Toxicity of Release	e (For Emissions Exceedances)	
	Unable to Quantify - 1		_
		Adjustment Factor 2	
		s Fibers are a Hazardous Air Pollutant	
	2. Environmental/Pu	ublic Health Risk (Proximity to sensitive environment or group)	_
	Negligible – 1x Modera	te – 1.5x Significant – 2x Adjustment Factor 1.0	
	Comment: Negligible		_
		Total Adjustment Factors (1 x 2) = 2	
	B. Adjusted Base Po	enalty	
	Base Penalty \$	\$.00
	C Number of Days	/Weeks/Months or Units in Violation	
	Adjusted Penalty \$	- \$ 10,000	.00
		lent of failing to conduct a thorough asbestos survey	
	Comment. (17 mora	icht of foling se services	
	D. Economic Benef	fit	
	Avoided Costs \$	0.00 + Delayed Costs \$ 0.00 = \$ 0.00)
	Comment: No avoid	ded or delayed costs were assessed	
	nalty Subtotal	10,000,00 + Economic Benefit \$ 0.00 = \$ 10,000	00
Adj	usted Base Penalty \$	10,000.00 + Economic Benefit \$ 0.00 = \$ 10,000	.00

III. Penalty Adjustment Consideration




Company Name	840 Street LLC	
Contact Name	Farshad Moftakhar	
Case Number	1504	
Violation Number	AQMV24-0033	
Violation of Section	40 CFR 61, Subpart M 61.145(b)	
Permit Condition	N/A	
I. Base Penalty as spec	cified in the Penalty Table = \$\frac{2,000.00}{}	
II. Severity of Violation	1	
A. Public Health Im	pact	
 Toxicity of Release Unable to Quantify - 1 	e (For Emissions Exceedances) x Criteria Pollutant - 1x Hazardous Air Pollutant - 2x Adjustment Factor 1	
Comment: Asbestos	Fibers are a Hazardous Air Pollutant	
	blic Health Risk (Proximity to sensitive environment or group)	
Negligible – 1x Moderat		
Comment: Negligibl		
; 	Total Adjustment Factors (1 x 2) = 1	
B. Adjusted Base Po		
Base Penalty \$	2,000.00 x Adjustment Factor 1 = \$ 2,000.00	
C. Number of Days/Weeks/Months or Units in Violation Adjusted Penalty \$ 2,000.00 x Number of Days/Weeks/Mortal = \$ 2,000.00 Comment: (1) Incident of failing to provide Notification per 40 CFR 61.145(b)		
<u> </u>		
D. Economic Benef Avoided Costs \$ Comment: No avoid	it O 00 + Delayed Costs \$ 0.00 = \$ 0.00 ded or delayed costs were assessed	
Penalty Subtotal	¢ - 200 00	
Adjusted Base Penalty \$	2,000.00 + Economic Benefit \$ 0.00 = \$ 2,000.00	

III. Penalty Adjustment Consideration




Comp	oany Name	840 Street LLC	
Conta	act Name	Farshad Moftakhar	
Case	Number	1504	
Viola	tion Number	AQMV24-0034	-
	tion of Section nit Condition	40 CFR 61, Subpart M 61.145(c)(6) N/A	_
i.	Base Penalty as spe	cified in the Penalty Table = \$ 2,500.00	
II.	Severity of Violation	1	
	A. Public Health Im	pact	
	1. Toxicity of Releas	e (For Emissions Exceedances)	
	Unable to Quantify - 1		
		Adjustment Factor 2	
		Fibers are a Hazardous Air Pollutant	_
	2. Environmental/Pu	blic Health Risk (Proximity to sensitive environment or group)	
		te – 1.5x Significant – 2x Adjustment Factor 2.0	
	Comment: Significa	Risk due to exposure to the public entering and residing in the building	
		Total Adjustment Factors (1 x 2) = 4	
	B. Adjusted Base P	enalty	
	Base Penalty	2,500.00 x Adjustment Factor 4 = \$ 10,000.	00
	Adjusted Penalty \$	/Weeks/Months or Units in Violation	00
	Comment: (2) Days	of failing to use proper procedures for asbestos emission control	_
	D. Economic Benef Avoided Costs \$ Comment: No avoi	it O:00 + Delayed Costs \$ 0.00 = \$ 0.00 ded or delayed costs were assessed	
	nalty Subtotal	20,000.00 + Economic Benefit \$ 0.00 = \$ 20,000	<u>00</u>
Adiι	usted Base Penalty \$	20,000.00 + Economic Benefit \$ 0.00 = \$ 20,000	

III. Penalty Adjustment Consideration




Comp	any Name	840 Street LLC			
Conta	ct Name	Farshad Moftakhar			
Case Number 1		1504			
Violat	ion Number	AQMV24-0035			
	tion of Section	40 CFR 61, Subpart M 61.145(c)(8) N/A			
I.	Base Penalty as specified in the Penalty Table = \$ 10,000.00			,000.00	
II.	Severity of Violation				
	A. Public Health Imp	act			
	1. Toxicity of Release	(For Emissions Exceedances)			
	Unable to Quantify - 1x	Criteria Pollutant - 1x Hazardous Air Pollutant - 2x	(
		Adjustment Factor		1	
	Comment: Unable to				
	2. Environmental/Pub	lic Health Risk (Proximity to sensitive environment or group)		# EV	
	Negligible – 1x Moderate	- 1.5x Significant - 2x Adjustment Factor		1.0	
	Comment: Negligible				
		Total Adjustment Factors (1 x 2) = 1		,	
	B. Adjusted Base Pe		,		
	Base Penalty \$	10,000.00 x Adjustment Factor1	- = \$	10,000.00	
	C. Number of Days/	Weeks/Months or Units in Violation	. .		
	Adjusted Penalty \$	10,000.00 x Number of Days/Weeks/Mol 1] = \$	10,000.00	
	Comment: (1) Incide	nt of failing to have a trained representative onsite			
	D. Economic Benefit				
	Avoided Costs \$	0.00 + Delayed Costs \$ 0.00	= \$	0.00	
		ed or delayed costs were assessed			
	:				
Pena	alty Subtotal				
Adius	sted Base Penalty \$	10,000.00 + Economic Benefit \$ 0.00	= \$	10,000.00	

III. Penalty Adjustment Consideration



Com	pany Name	840 Street LLC			
Cont	act Name	Farshad Moftakhar			
Case Number		1504			
Viola	ition Number	AQMV24-0036			
Viola	ntion of Section	030.1401 - Stop Work Order			
	nit Condition	N/A			
l.	Base Penalty as specified in the Penalty Table = \$ 10,000.00				
11.	Severity of Violatio	n			
	A. Public Health Im	npact			
	Unable to Quantify - 1	Adjustment Factor 1			
		to Quantify			
		ublic Health Risk (Proximity to sensitive environment or group) ate = 1.5x, Significant = 2x Adjustment Factor 1.0			
		gre-1.5x Significant-2x			
	Comment: Negligib				
		Total Adjustment Factors (1 x 2) = 1			
B. Adjusted Bas		Penalty			
	•	\$ 10,000.00 x Adjustment Factor 1 = \$ 10,000.00			
	C. Number of Days	s/Weeks/Months or Units in Violation			
	Adjusted Penalty \$				
	Comment: (1) Incid	dent of failing to comply with a Stop Work Order issued by the AQMD			
	D. Economic Bene				
	Avoided Costs \$	0.00 + Delayed Costs \$ 0.00 = \$ 0.00			
	Comment: No avo	ided or delayed costs were assessed			
	/. ===				
	nalty Subtotal	10,000,00 + Economic Benefit \$ 0.00 = \$ 10,000.00			
۸dii	isted Rase Penalty S	10.000.00 + Economic Benefit \$ 0.00 = \$ 10,000.00			

III. Penalty Adjustment Consideration





MEMORANDUM OF UNDERSTANDING

NORTHERN NEVADA PUBLIC HEALTH AIR QUALITY MANAGEMENT DIVISION

Date:12/09/2024	
Company Name: 840 Street, LLC	
Address: 840 Street, Sparks, Nevada	
Case No. 1504 N	otice of Violation No.(s) AQMV24-0032,
AQMV24-0033, AQMV24-0034, AQMV24-0	
The staff of the Northern Nevada Public Healt above referenced citation for the violation of Regula 40 CFR 61 Subpart M - Asbestos §61.145(a), 4	
40 CFR 61 Subpart M - Asbestos §61.145(c	
§61.145(c)(8), DBOH Regulations PART 020	0.100 B – Stop Work Order (Suspension)
<u> </u>	The state of the state (Gaspansion)
A settlement of this matter has been negotiated penalty amount of \$\frac{46,800.00}{80000000000000000000000000000000	his settlement will be submitted to the District d meeting on January 23, 2025. Air Pollution Control Hearing Board so this matter
	C/ol C. Vet
Signature of Company Representative	Signature of District Representative
Farshad Moftakha	Joshua C. Restari
Print Name	Print Name
Title	Title
affer ?	VILLE 10
Witness	Witness

AIR QUALITY MANAGEMENT DIVISION

1001 East Ninth Street, Building B-171, Reno, Nevada 89512

AQMD Office: 775-784-7200 | Fax: 775-784-7225 | OurClean Air.com

Serving Reno. Sparks and all of Washoe County, Nevada